

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Fuse-link, NH-System

Name and address of the applicant

Mersen France SB S.A.S.  
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE  
MURE, FRANCE

Name and address of the manufacturer

Mersen France SB S.A.S.  
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE  
MURE, FRANCE

Name and address of the factory

FUSETECH Kft.  
Guba Sandor ut. 38, 7400 KAPOSVAR  
HUNGARY*Note: When more than one factory, please report on page 2* Additional Information on page 2

Ratings and principal characteristics

see additional information on page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NH2GG50Vxxx; NH2GG50Vxxx-1,  
NH22GG50Vxxx; NH22GG50Vxxx-1Additional information (if necessary may also  
be reported on page 2)


see additional information on page 2

 Additional Information on page 2A sample of the product was tested and found  
to be in conformity withIEC 60269-1:2006  
IEC 60269-1:2006/AMD1:2009  
IEC 60269-2:2013  
IEC 60269-2:2013/AMD1:2016As shown in the Test Report Ref. No. which  
forms part of this Certificate

230292-CC2-1; 230292-CC2-2

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierung Produkte / Certification Products



Date: 2017-01-30

Signature:

J. Richter

**Additional information (if necessary)****Un: 500V a.c.****Breaking capacity: 120 kA****Characteristic: gG****Size: 2****Type / In:****NH2GG50Vxxx (energized / compact size) 35 ... 250A****NH2GG50Vxxx-1 (de-energized / compact size) 35 ... 250A****NH2GG50Vxxx (energized / normal size) 315 ...400A****NH2GG50Vxxx-1 (de-energized / normal size) 315 ...400A****NH22GG50Vxxx (energized / normal size) 63 ...250A****NH22GG50Vxxx-1 (de-energized / normal size) 63 ...250A**

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
 Zertifizierung Produkte / Certification Products



Date: 2017-01-30

Signature: J. Richter