



# Certificate of Compliance

**Certificate:** 1167001 **Master Contract:** 162842 (032169\_0\_000)

**Project:** 70116338 **Date Issued:** 2017-01-12

**Issued to:** Mersen USA Newburyport-MA, LLC  
374 Merrimac St  
Newburyport, Massachusetts 01950-1998  
USA  
**Attention:** Marla Miller

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicator ▲*



**Issued by:** *Ramana Tangirala*  
Ramana Tangirala

## **PRODUCTS**

CLASS - C622530 - FUSEHOLDER ASSEMBLIES– Cartridge Type-Component Acceptance Program

Extractor Type Fuseholder Assemblies, **Cat. No. US14 (Alternate Cat No. CMS 14)**, 50A, 800V ac max, 1000V dc max and **Cat. No. US22 (Alternate Cat No. CMS22)**, 125A, 800V ac max, 1000V dc max; followed with suffixes, for Semiconductor fuse Application with Ferraz Type gF, gI-gG and aM fuses, with or without Blown Fuse Indicator, DIN Rail Mounting - NOT FOR DISCONNECTING MEANS.

### Note:

1. Certified for use only as components in other equipment where the suitability of the combination is determined by the CSA Group.
2. These devices have not been investigated for use as disconnect devices and should not be operated under load.
3. Temperature rise values should be evaluated under end use application. Maximum allowable fuseholder body temperature 120C.

## **APPLICABLE REQUIREMENTS**

CSA Std. C22.2 No. 39 - Fuseholder Assemblies  
CSA Std. C22.2 No. 14 - Industrial Control Equipment



## *Supplement to Certificate of Compliance*

**Certificate:** 1167001

**Master Contract:** 162842 (032169\_0\_000)

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

<b>Project</b>	<b>Date</b>	<b>Description</b>
70116338	2017-01-12	covers transfer of Cat. No. US14 (Alternate Cat No. CMS 14) and Cat. No. US22 (Alternate Cat No. CMS22) from Class 3211-37 to 6225-30
2724062	2014-05-14	covers alternate construction of Toggle Material as covered under Item 3 and 5 and alternate Trip Levers material under Item 2 of Trip indicator Switch Module.. Also covers product evaluation to revised CSA standard C22.2 No. 39-13.
1841608	2006-10-16	To Cover alternate Cat. Ref "CMS", voltage uprate to 800V ac/1000V dc; Alternate plastic material for case (Type B3UG4, Latamid 6H2G9(k) V2HF and Kelon AFRH2 T/35-V2 ) and Toggle (Type B3UG4 and Polyone A700G25US0).
1251604	2001-10-17	covers alternate toggle material for US14 and US22
1167001 US14 and US22	2001-05-15	Covers original certification of Extractor Type Fuseholder Assemblies, Cat. No.