

# Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

<b>Manufacturer</b>	<b>Mersen France SB S.A.S.</b>
<b>Address</b>	15 Rue Jacques de Vaucanson, 69720 Saint Bonnet De Mure, France
<b>Place of Production</b>	NOLAM TUNISIA Rue de Nabeul, Lot No.4 Zone, Industrielle de M'Ghira, Tunisia
<b>Type</b>	Plastic fuse bases Types EP,TP,PP for fuse links NH type sizes 00,0,1,2,3 for 1 to 4 poles
<b>Description</b>	Low voltage HRC Fuse Bases
<b>Application</b>	Marine, applications for switchboard
<b>Specified Standard</b>	IEC 60269-1, IEC 60269-2

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

**Peter Huntley-Hawkins**

Principal Specialist to Lloyd's Register EMEA  
A member of the Lloyd's Register group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

## Type Approval Certificate

### Ratings

Plastic fuse bases Types EP,TP,PP for fuse links NH type sizes 00,0,1,2,3 for 1 to 4 poles

Type	Rating:
BB00	690V, 12W
BB01	690V, 25W
BB02	690V, 25W
BB03	690V, 25W
BB04	690V, 25W
BB11	690V, 32W
BB12	690V, 32W
BB13	690V, 32W
BB14	690V, 32W
BB21	690V, 45W
BB22	690V, 45W
BB23	690V, 45W
BB24	690V, 45W
BB31	690V, 60W
BB32	690V, 60W
BB33	690V, 60W
BB34	690V, 60W

### Additional Tests

ENV 1 and ENV2 as defined in LR Test Specification No1, 2019

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document LR2187253TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.