Certificate of Compliance

Certificate Number:

UL-US-2593757-0

Report Reference:

E523293-20251128

Issue Date:

2025-11-27

Issued to:

MERSEN SHANGHAI CO LTD
#6, #7, #8 No 55 Shushan Rd Songjiang
NO 55 SHUSHAN ROAD Shanghai 201611
China

This certificate confirms that representative samples of:

JFHR2 - Special-purpose Fuses - Component

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.

UL 248-1, 4th Ed., Issue Date: 2022-10-24, UL 248-13, Edition 3, Issue Date 2022-03-31

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Recognized Component Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number	UL-US-2593757-0
Report reference	E523293-20251128
Date	2025-11-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fuses - Special Purpose

Model(s): D100A, followed by 150, 175 or 200, followed by -30B. *Maybe followed by additional letters and/or numbers. Ampere rating 150 – 200A, voltage rating 1000Vdc.*
Model(s): Cat. No. D100A, followed by 250 or 300, followed by -38B. *Maybe followed by additional letters and/or numbers. Ampere rating 250 – 300A, voltage rating 1000Vdc.*
Model(s): Cat. No. D100A, followed by 350 or 400, followed by -50B. *Maybe followed by additional letters and/or numbers. Ampere rating 350 – 400A, voltage rating 1000Vdc.*
Model(s): Cat. No. D100A, followed by 450, 500, 550 or 600, followed by -60B. *Maybe followed by additional letters and/or numbers. Ampere rating 450 – 600A, voltage rating 1000Vdc.*

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.

Form-ULID-019496 – ver 1.0